

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6912-0328:157 Page 1 of 1

CATEGORY: Voice Communication Accessories

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Models PAU-360, PDVS-25 and PDVS-50 audio adjunct system; Model PAU-562-2 remote microphone station.

Models PAU-360, PDVS-25 and PDVS-50 audio adjunct systems consist of a signal generator, microphone, power amplifier, output transformer and switching and interface circuits to provide a voice-tone communication system adjunct for use with any separately listed compatible fire alarm control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 24VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 72 and in a manner acceptable to the authority having jurisdiction. Supervision is dependent upon the control unit. Power to the modules and the speaker circuits are intended to be supervised through the bell circuit of the control unit. All units except Model PAU-562-2 and PDVS-25 and PDVS-50 are to be mounted adjacent to the fire alarm control panel. Model PAU-562-2 must be installed in a listed back box.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice-tone communication unit when used with separately listed compatible fire alarm control units and speakers.

XLf: 6912-1408:108

02-04-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**